

110 Summary

utions.
r safety

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

CONTACT THE TM OPTIMISER

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₃	P	Other Specify	FE Temp °C
DDP TEST - 190 DEAERED DECANT PUMP	47	WINDY	✓	SC	25	2.70	0.9	0.69	17.0
						4.4			
	32	COOL CICAST	OK	FF	25	0.47	0.7	0.39	17.9
SHT DEWATERING EMAIL TO [REDACTED] TO ARRANGE RAG SKIP TO BE CHANGED	53	LIGHT RAIN	✓	SC	25	1.08	1.1	0.47	15.6
possible faulty float. Chamber stopped at correct level. However two English tanks not aired up before. Will order new floats.									
Heavy rain and High flows overnight. SFF feed well bypassing. Excubation form sent for NH ₃	62	wet	✓	SC	10	3.18	0.7	0.67	17.0°C
De-aerial Ligner Pump 1. Dewatered SHT	61	Sunny	✓	SC	5	0.87	0.7	0.38	16.8°C