

You are reminded that Site Log Books are official documents and comments must be restricted to operational information and actions. Please write clearly and ensure that you sign in and out at all times. If you are concerned about any aspect of site performance or safety please contact your Line Manager as soon as you can.

Comments	Flow l/s	Weather Conditions	Site Security Checks	Samples					
				Visual Check	SS	NH ₄	P	Other Specify	FE Temp °C
NEW pulsar ordered									
	27	cloudy	✓	SC	45	0.31	0.8	0.45	17.6
SHT LEFT OF WATERING. SKIP DUG TO BE CHANGED TODAY.	50	cloudy	✓	MF	45	0.76	1.2	0.70	16.8
Ferric-19.66m ³ Sludge tank cracked to de water.	32	cloudy	✓	SC	10	0.11	0.9	1.02 ^{iron}	17.3
PST'S de Sludged to Water. Sludge tank cracked to de water.	37	Sunny	✓	SC	45	1.13	0.8	0.89 ^{iron}	17.7