


From: no-reply-InFlow@anglianwater.co.uk
Sent: 11 August 2025 14:49
To: planning
Subject: Discharge of Condition




Land South Of 8 - 59 Fairbairn Way Chatteris Cambridgeshire, F/YR25/3097/COND, PLN-0231321

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: We have not been asked to comment on a foul condition at this time.

Surface Water Comments: Drawing 26461-124 states 'Detention basin maintenance Inlet and outlet headwalls to be maintained by Anglian Water. Other basin maintenance (gras cutting etc.) to be undertaken by' but doesn't clarify who will be undertaking this. We therefore are not able to recommend discharge of condition 6 at this time

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or  quoting reference PLN-0231321.

Kind Regards

Development Services Pre-Development Team

Not you or need help?

Call us on **0345 60 66 087**



This is an automatically generated email, please do not reply to this message.

Anglian Water Services Limited. Registered Office: Henderson House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU. Registered in England: No. 2366656. An AWG Company.