

From: no-reply-InFlow@anglianwater.co.uk
To: [planning](#)
Subject: Discharge of Condition
Date: 28 February 2022 14:21:57



Dear [REDACTED]

**Land At Womb Farm Doddington Road Chatteris Cambridgeshire,
F/YR21/3140/COND, PLN-0142001**

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: We note the the flow rate of 12.4l/s has been based on DCG figures. There is insufficient capacity in the receiving network to accommodate a rate of 12.4l/s. We would suggest a pumped rate of 5l/s, this is based on figured from Minimum Asset standards (MAS). A rate of 5l/s would be acceptable at the marked connection point. Until such time that an acceptable rate is agreed, we would not recommend discharge of condition 19 of planning reference F/YR19/0834/O.

Surface Water Comments:

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or 07929 786 955 quoting reference PLN-0142001.

Kind Regards
Development Services Pre-Development Team

Not you or need help?

Call us on **0345 60 66 087**



This is an automatically generated email, please do not reply to this message.
Anglian Water Services Limited. Registered Office: Henderson House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU. Registered in England: No. 2366656. An AWG Company.

*-----
The information contained in this message is likely to be confidential and may be legally privileged. The dissemination, distribution, copying or disclosure of this message, or its contents, is strictly prohibited unless authorised by Anglian Water. It is intended only for the person named as addressee. Anglian Water cannot accept any responsibility for the accuracy or completeness of this message. Contracts cannot be concluded with us by email or using the Internet. If you have received this message in error, please

