

From: [Planning Liaison](#)
To: [planning](#)
Subject: Land West And South Of 74 West Street Chatteris Cambridgeshire – F/YR23/0940/F
Date: 24 November 2023 03:14:19
Attachments: [PLN-0199530 - Planning Report.pdf](#)

Dear [REDACTED],

Our Reference: PLN-0199530

Please see attached our response for the planning application – Land West And South Of 74 West Street Chatteris Cambridgeshire – F/YR23/0940/F

Please do not hesitate to contact the Planning & Capacity Team on the number below or via email should you have any questions related to our planning application response.

Kind regards

[REDACTED]

Planning & Capacity Team

Development Services

Telephone: [REDACTED]

Anglian Water Services Limited

Thorpe Wood House, Thorpe Wood, Peterborough,
Cambridgeshire, PE3 6WT

---*---

The information contained in this message is likely to be confidential and may be legally privileged. The dissemination, distribution, copying or disclosure of this message, or its contents, is strictly prohibited unless authorised by Anglian Water. It is intended only for the person named as addressee.

Anglian Water cannot accept any responsibility for the accuracy or completeness of this message, and does not authorise any contract to be made using the Internet.

If you have received this message in error, please immediately return it to the sender at the above address and delete it from your computer.

Anglian Water Services Limited

Registered Office: Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire, PE29 6XU

Registered in England No 2366656

Please consider the environment before printing this email.



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email planningliaison@anglianwater.co.uk

AW Site Reference: 208808/1/0199530

Local Planning Authority: Fenland District

Site: Land West And South Of 74 West Street
Chatteris Cambridgeshire

Proposal: Erect 70 x dwellings (29 x 2-bed 2-storey, 29 x 3-bed 2-storey, 6 x 4-bed 2-storey and 6 x 2-bed single-storey)

Planning application: F/YR23/0940/F

Prepared by: Pre-Development Team

Date: 24 November 2023

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Chatteris-Nightlayer Fen Water Recycling Centre that will have available capacity for these flows

Section 3 - Used Water Network

This response has been based on the following submitted documents: Preliminary Drainage Strategy Report dated July 2023, Drainage Areas Layout dated July 2023 Revision C and Flood Risk Assessment and Drainage Strategy. The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. **INFORMATIVE** - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087.
2. **INFORMATIVE** - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water.
3. **INFORMATIVE** - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087.
4. **INFORMATIVE**: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

We note the applicant states the onsite sewers will be adopted by Anglian Water. We would recommend that the applicant engages with Anglian Water direct regarding their on site sewers. Anglian Water encourage the use of SuDS and if the developer wishes us to be the adopting body for all or part of the proposed SuDS scheme the Design and Construction Guidance must be followed. We would recommend the applicant contact us at the earliest opportunity to discuss their on site sewers and if require their SuDS design via a Pre-Design Strategic Assessment (PDSA) form available on our website Sustainable drainage systems (anglianwater.co.uk), or please contact planningliaison@anglianwater.co.uk The lead local flood authority is the statutory consultee for all surface water drainage systems on major developments and should be contacted as soon as possible regarding the proposal.

Section 5 - Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

Assets Affected (Section 1)

We need to inform you that a 250mm sewer rising main and a 300mm combined sewer which cross the development site and is affected by the proposed development. Anglian Water does not permit this asset to be located within the curtilage of a dwelling. This asset(s) should be located in areas of public open space and/or adoptable highways to ensure on-going maintenance is possible. The proposed site layout plan and drainage layout areas plan is not clear that these assets owned by Anglian Water have been taken in consideration.

The site layout plan, as submitted, indicates that the above asset will be located within attenuation basin areas. We would like to request an extension of time to the consultation period to enable us to liaise with the applicant and discuss a suitable solution. The applicant can contact us at: planningliaison@anglianwater.co.uk

FOR THE ATTENTION OF THE APPLICANT - if Section 3 or Section 4 condition has been recommended above, please see below information:

Next steps

Desktop analysis has suggested that the proposed development will lead to an unacceptable risk of flooding downstream. We therefore highly recommend that you engage with Anglian Water at your earliest convenience to develop in consultation with us a feasible drainage strategy.

If you have not done so already, we recommend that you submit a Pre-planning enquiry with our Pre-Development team. This can be completed online at our website <http://www.anglianwater.co.uk/developers/pre-development.aspx>

Once submitted, we will work with you in developing a feasible mitigation solution.

If a foul or surface water condition is applied by the Local Planning Authority to the Decision Notice, we will require a copy of the following information prior to recommending discharging the condition: