

Dear [REDACTED]

Land At Womb Farm Doddington Road Chatteris Cambridgeshire, F/YR21/3140/COND, PLN-0141777

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: Anglian Water has reviewed CONDITION 9, 11, 12 AND 19 INFORMATION PACK, which does not include a clear drainage strategy detailing the point of connection, regime and rate of discharge into the public sewer network. At this time, we do not recommend discharging condition 19 from reference F/YR21/3140/COND

Surface Water Comments:

Should you have any queries or comments regarding this please contact us at

[REDACTED] or [REDACTED] quoting reference PLN-0141777.

Kind Regards

Development Services Pre-Development Team