



## Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk)

AW Site Reference: 200118/1/0171888

Local Planning Authority: Fenland District

Site: Land South Of Caravan Site Fenland Way  
Chatteris Cambridgeshire

Proposal: Erect 31 x dwellings (6 x 2-storey 2-bed, 6 x 2-storey 3-bed, 9 x 2-storey 4-bed, 8 x 3-storey 3-bed, 2 x 3-storey 4-bed)

Planning application: F/YR23/0155/F

**Prepared by:** Pre-Development Team

**Date:** 13 March 2023

### ASSETS

#### Section 1 - Assets Affected

Our records show that there are no assets owned by Anglian Water or those subject to an adoption agreement within the development site boundary.

### WASTEWATER SERVICES

#### Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Chatteris-Nightlayer Fen Water Recycling Centre which currently does not have capacity to treat the flows the development site. Anglian Water are obligated to accept the foul flows from the development with the benefit of planning consent and would therefore take the necessary steps to ensure that there is sufficient treatment capacity should the Planning Authority grant planning permission.

### Section 3 - Used Water Network

This response has been based on the following submitted documents: DRAINAGE REPORT January 2023 reference REF 1090-00-002 Due to lack of information we are unable to make an informed assessment. The applicant indicates that the foul drainage is to be connected into a private network and therefore a full assessment cannot be made. The applicant has not identified a connection point into the Anglian Water network. We would require a drainage strategy to be submitted indicating the point of connection into Anglian Water network. Therefore, the development has the potential to have an unacceptable risk of flooding/or pollution from the network. Anglian Water will need to plan effectively for the proposed development, if permission is granted. We will need to work with the applicant to ensure any infrastructure improvements are delivered in line with the development. We therefore request a condition requiring phasing plan and/or on-site drainage strategy INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

### Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

The applicant has indicated on their application form that their method of surface water drainage is via SuDS. It is quoted that the private network will be to Anglian Water for adoption of these sewers. If the developer wishes Anglian Water to be the adopting body for all or part of the proposed SuDS scheme the Design and Construction Guidance must be followed. We would recommend the applicant contact us at the earliest opportunity to discuss their SuDS design via a Pre-Planning Strategic Enquiry. The Lead Local Flood Authority (LLFA) are a statutory consultee for all major development and should be consulted as early as possible to ensure the proposed drainage system meets with minimum operational standards and is beneficial for all concerned organisations and individuals. We promote the use of SuDS as a sustainable and natural way of controlling surface water run-off. We please find below our SuDS website link for further information. <https://www.anglianwater.co.uk/developers/drainage-services/sustainable-drainage-systems/>

### Section 5 - Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

#### Used Water Sewerage Network (Section 3)

.We have no objection subject to the following condition: Condition Prior to the construction above damp proof course, a scheme for on-site foul water drainage works, including connection point and discharge rate, shall be submitted to and approved in writing by the Local Planning Authority. Prior to the occupation of any phase, the foul water drainage works relating to that phase must have been carried out in complete accordance with the approved scheme. Reason To prevent environmental and amenity problems arising from flooding

**FOR THE ATTENTION OF THE APPLICANT - if Section 3 or Section 4 condition has been recommended above, please see below information:**

**Next steps**

Desktop analysis has suggested that the proposed development will lead to an unacceptable risk of flooding downstream. We therefore highly recommend that you engage with Anglian Water at your earliest convenience to develop in consultation with us a feasible drainage strategy.

If you have not done so already, we recommend that you submit a Pre-planning enquiry with our Pre-Development team. This can be completed online at our website <http://www.anglianwater.co.uk/developers/pre-development.aspx>

Once submitted, we will work with you in developing a feasible mitigation solution.

If a foul or surface water condition is applied by the Local Planning Authority to the Decision Notice, we will require a copy of the following information prior to recommending discharging the condition:

**Foul water:**

- Feasible drainage strategy agreed with Anglian Water detailing the discharge solution including:
  - Development size
  - Proposed discharge rate (Should you require a pumped connection, please note that our minimum pumped discharge rate is 3.8l/s)
  - Connecting manhole discharge location (No connections can be made into a public rising main)
- Notification of intention to connect to the public sewer under S106 of the Water Industry Act (More information can be found on our website)
- Feasible mitigation strategy in agreement with Anglian Water (if required)