



Planning Applications – Suggested Informative Statements and Conditions Report

AW Reference: 00007759
Local Planning Authority: Fenland District
Site: Land West And South Of 74 West Street,
Chatteris
Proposal: Erection of 58 Dwellings
Planning Application: F/YR15/0512/O

Prepared by [REDACTED]

Date 20 July 2015

If you would like to discuss any of the points in this document please contact me on 01733 414690 or email planningliaison@anglianwater.co.uk

ASSETS

Section 1 – Assets Affected

- 1.1 There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

"Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence."

WASTEWATER SERVICES

Section 2 – Wastewater Treatment

- 2.1 The foul drainage from this development is in the catchment of Chatteris Water Recycling Centre that will have available capacity for these flows.

Section 3 – Foul Sewerage Network

- 3.1 Development will lead to an unacceptable risk of flooding downstream. A drainage strategy will need to be prepared in consultation with Anglian Water to determine mitigation measures.

We request a condition requiring the drainage strategy covering the issue(s) to be agreed.

Section 4 – Surface Water Disposal

- 4.1 The surface water strategy/flood risk assessment submitted with the planning application is not relevant to Anglian Water and therefore this is outside our jurisdiction for comment and the Planning Authority will need to seek the views of the Environment Agency.

We request that the agreed strategy is conditioned in the planning approval.

Section 5 – Trade Effluent

- 5.1 Not applicable.

Section 6 – Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

Foul Sewerage Network (Section 3)

CONDITION

No development shall commence until a foul water strategy has been submitted to and approved in writing by the Local Planning Authority. No dwellings shall be occupied until the works have been carried out in accordance with the foul water strategy so approved unless otherwise approved in writing by the Local Planning Authority.

REASON

To prevent environmental and amenity problems arising from flooding.
