

[REDACTED]

From: EIR
Sent: 07 April 2025 15:56
To: [REDACTED]
Subject: [REDACTED]

Dear requester

Provision of requested information

Thank you for your request for information about sewer relining, which we received on 07 April 2025. Your request has been considered under the Environmental Information Regulations 2004.

1. Are sewer relining techniques currently being utilised as an ongoing remedial measure for your existing foul and surface water asset network? **Yes**
2. If not, have sewer relining techniques been used historically as a remedial measure for your existing foul and surface water asset network? If so, when did sewer relining techniques stop being used? **n/a**
3. Which of the following sewer relining methods are being utilised at present:
 1. CIPP (Cured In Place Pipe) Lining - **Yes - depends on the situation**
 2. Slip lining - **Yes - depends on the situation**
 3. Spray/brush applied unreinforced internal pipe coating (Epoxy, Resin, Polyurethane etc) - **Yes - depends on the situation**
 4. Cement Mortar Lining (reinforced/unreinforced) - **Yes - depends on the situation**
 5. Concentric Pipe Reduction Systems
 6. Spirally Wound Lining (PVC etc)
 7. Other
4. Are sewer relining techniques only utilised to remediate displaced joints, and repair radial/longitudinal cracks in your existing foul/surface water sewer assets only? **No**
5. If not, are any sewer relining methods deemed an appropriate repair for collapsed pipes for your existing foul/surface water sewer assets? - **Yes - depends on the situation**
6. Is pipe bursting currently being utilised as a repair method for your existing foul/surface water sewer assets? - **Yes**

The information supplied to you continues to be protected by the Copyright, Designs and Patents Act 1988. You are free to use it for your own purposes, including any non-commercial research you are doing, and for the purposes of news reporting. Any other re-use (for example, commercial publication) would require the permission of the copyright holder. It is important that this data is not published for security reasons.

If you are unhappy with the service you have received in relation to your request and wish to request an internal review, you should email EIR@anglianwater.co.uk or write to:

Legal Director, Anglian Water Services, Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon PE29 6XU

If you are not content with the outcome of the internal review, you have the right to apply directly to the Information Commissioner for a decision. The Information Commissioner can be contacted at:

Information Commissioner's Office, Wycliffe House, Water Lane, Wilmslow, Cheshire SK9 5AF

If you have any queries about this email, please contact me.

Yours sincerely

EIR Team

Anglian Water Services Limited

Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU

Email EIR@anglianwater.co.uk