



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email planningliaison@anglianwater.co.uk.

AW Site 204860/1/0182968
Reference:

Local Aylesbury Vale District
Planning
Authority:

Site: Land West Of Moreton Road And
Castlemilk Buckingham Buckinghamshire

Proposal: Erection of 130 dwellings, associated
access and parking, landscaping and
amenity space and the change of land from
agriculture to use as sports
pitches/recreational open space and
informal open space.

Planning 20/00510/APP
application:

Prepared by: Pre-Development Team

Date: 14 July 2023

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Buckingham Water Recycling Centre which currently does not have capacity to treat the flows the development site. Anglian Water are obligated to accept the foul flows from the development with the benefit of planning consent and would therefore take the necessary steps to ensure that there is sufficient treatment capacity should the Planning Authority grant planning permission.

Section 3 - Used Water Network

This response has been based on the following submitted documents: FRA 21 March 2022 The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection. (1) INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. (2) INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. (3) INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. (4) INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. (5) INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

Anglian Water has reviewed the submitted documents (FRA 21 March 2022) and can confirm that these are acceptable to us at a maximum of 14l/s. We require these documents to be listed as approved plans/documents if permission is granted. Note to applicant – Surface Water Hierarchy evidence will need to be submitted at 106 application stage before any connection to the public surface water sewer will be permitted.