



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email planningliaison@anglianwater.co.uk

AW Site Reference: 210634/1/0206521

Local Planning Authority: Breckland District

Site: Land South of Mattishall Road NR20 3SF

Proposal: Development of 19 dwellings, garaging, open space, vehicular and pedestrian access, highway improvements, drainage, and other associated works and infrastructure; continued use of East Tuddenham recreation ground for recreational purposes.

Planning application: 3PL/2023/1211/F

Prepared by: Pre-Development Team

Date: 12 April 2024

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

The development site is within 15 metres of a sewage pumping station. This asset requires access for maintenance and will have sewerage infrastructure leading to it. For practical reasons therefore it cannot be easily relocated.

Anglian Water consider that dwellings located within 15 metres of the pumping station would place them at risk of nuisance in the form of noise, odour or the general disruption from maintenance work caused by the normal operation of the pumping station.

The site layout should take this into account and accommodate this infrastructure type through a necessary cordon sanitaire, through public space or highway infrastructure to ensure that no development within 15 metres from the boundary of a sewage pumping station if the development is potentially sensitive to noise or other disturbance or to ensure future amenity issues are not created.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Mattishall Water Recycling Centre that will have available capacity for these flows

Your development site is served by Mattishall Recycling Centre, the outfall for which discharges outside of the Natural England Nutrient Neutrality boundary

Section 3 - Used Water Network

This response has been based on the following submitted documents: Flood Risk Assessment and Drainage Strategy 182/2023/FRADS dated March 2024 Version 2 The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection. 1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. 2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. 4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements."

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

From the Flood Risk Assessment and Drainage Strategy 182/2023/FRADS dated December 2023 submitted to support the planning application the proposed method of surface water management does not relate to Anglian Water. As such, we are unable to provide comments on the suitability of the surface water management. The applicant and the Local Planning Authority should seek the advice of the Lead Local Flood Authority, as they are the statutory consultee for surface water management, and the Internal Drainage Board if applicable. The Environment Agency should be also consulted if the drainage system directly or indirectly involves the discharge of water into a Main River.