

[REDACTED]

From: EIR
Sent: 01 December 2025 10:58
To: [REDACTED]
Subject: [REDACTED]

Dear Requester

Thank you for your request for information about capacity at Campton, which we received on 4 November 2025. Your request has been considered under the Environmental Information Regulations 2004 (EIR).

You requested:

1. What is the capacity at the sewerage works that serves Campton
2. Are there any plans to increase capacity at the works that serves Campton

EIR Response: Provision of Requested Information

Item 1 is held by Anglian Water and has been provided below.

Campton is served by the Clifton Water Recycling Centre.

Clifton Water Recycling Centre (WRC) operates under a numeric environmental permit issued by the Environment Agency.

The WRC consent permit is for 2931m³ per day.

The permit is a defined limit on Dry Weather Flow (DWF) - the volume of treated effluent that can be discharged to the receiving watercourse.

The WRC was operating at 3245m³ per day as of the 2024 Q90 DWF data, which equates to running at 110.7% of the permit

Item 2 is held by Anglian Water and has been provided below.

We can confirm that Clifton WRC is included within our Business Plan as a named AMP 8 growth scheme, with investment delivery planned between 2025-2030.

IMPORTANT: The information supplied to you continues to be protected by the Copyright, Designs and Patents Act 1988. You are free to use it for your own purposes, including any non-commercial research you are doing, and for the purposes of news reporting. Any other re-use (for example, commercial publication) would require the permission of the copyright holder. It is important that this data is not published for security reasons.

If you are unhappy with the service you have received in relation to your request and wish to request an internal review, you should email EIR@anglianwater.co.uk or write to:

General Counsel, Anglian Water Services, Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon PE29 6XU

If you are not content with the outcome of the internal review, you have the right to apply directly to the Information Commissioner for a decision. The Information Commissioner can be contacted at:

Information Commissioner's Office, Wycliffe House, Water Lane, Wilmslow, Cheshire SK9 5AF

If you have any queries about this email, please contact us via EIR@anglianwater.co.uk.

Yours sincerely

EIR Team

Anglian Water Services Limited

Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU

Email EIR@anglianwater.co.uk