



Planning Applications – Anglian Water Objection

If you would like to discuss any of the points in this document please contact us on 0345 0263912 or email planningliaison@anglianwater.co.uk.

AW Site Reference: 228816/1/0232426

Local Planning Authority: Huntingdonshire District

Site: Land North Of Orchard Estate Station Road Bluntisham

Proposal: Outline application with all matters reserved except for access for up to 140 dwellings (Use Class C3), functional open space and associated works

Planning application: 25/01675/OUT

Prepared by: Pre-Development Team

Date: 26 September 2025

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

Anglian Water objects to the proposed development under Planning Application 25/01675/OUT due to the intended connection to the public foul drainage network.

This site is located within the catchment of the Somersham Water Recycling Centre (WRC), which currently lacks the capacity to accommodate the additional flows that would be generated by the proposed development. Anglian Water has determined that the site is unsustainable due to the associated environmental risk and the increased discharge rates, which could lead to a deterioration in water quality and an unacceptable risk of breaching environmental legislation at Somersham WRC.

Considering these concerns, we recommend that planning permission be refused on the grounds of insufficient infrastructure capacity and to prevent environmental harm.

Anglian Water collaborates with local planning authorities across the region to identify sustainable locations for future development, taking into account infrastructure capacity as part of the development plan processes.

We also work closely with our regulators to identify opportunities for future growth investment. At present, no funding has been allocated at this Water Recycling Centre (WRC) for AMP 8 (2025- 2030). However, we may seek to promote investment through our future business plans.

Section 3 - Used Water Network

This response has been based on the following submitted documents:

DRAINAGE MANAGEMENT STRATEGY SEPT 2025 REV 1.1/FRA AUGUST 2025 REV 1.0.

The sewerage network at present has available capacity for the anticipated foul flows. However as advised above, any connection into our foul network from the proposed development will contribute to pollution and deterioration of the watercourse via the WRC as it cannot accommodate additional flows. If the LPA is minded to grant approval despite our WRC objection, the developer will need to serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection. 1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2. 2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087 Option 2. 4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

From the details submitted to support the planning application the proposed method of surface water management does not relate to Anglian Water operated assets. As such, we are unable to provide comments on the suitability of the surface water management. The Local Planning Authority should seek the advice of the Lead Local Flood Authority or the Internal Drainage Board. The Environment Agency should be consulted if the drainage system directly or indirectly involves the discharge of water into a watercourse.

If planning permission is granted the strategy should be listed within the decision notice with any approved plans.

Should the proposed method of surface water management change to include interaction with Anglian Water operated assets, we would wish to be re- consulted to ensure that an effective surface water drainage strategy is prepared and implemented.

