



From: EIR
Sent: 10 December 2025 13:56
To: [Redacted]
Subject: [Redacted]

Dear Requester

Thank you for your request for information about storm overflows on the River Blyth, which we received on 9 December 2025. Your request has been considered under the Environmental Information Regulations 2004 (EIR).

You requested:

1. The location of storm overflows which are waiting for permits on the River Blyth
2. The status of the storm overflows at Halesworth.
3. Has the EDM at Laxfield Pumping Station activated.


EIR Response: Provision of Requested Information

Item 1 is held by Anglian Water and has been provided below.

Walpole No2 PS AWS01574 is the only unpermitted CSO in the area.

Item 2 is held by Anglian Water and has been provided below.

The overflows at Halesworth are shown as the same dot on the map. If you click on the dot the pop up box will appear



At the bottom right hand corner there is a toggle box which allows you to switch between the 2 EDMs.

Item 3 is not held by Anglian Water.

We have no records of Laxfield being manually entered into maintenance. Therefore, this implies that it was offline for a period of time, due to delayed or lost comms from the outstation and automatically applied. Once comms is regained, the map will be updated with the most recent activity. At present the EDM is reporting live and functioning on the map. However, we do not have visibility of historically applied offline status.

IMPORTANT: The information supplied to you continues to be protected by the Copyright, Designs and Patents Act 1988. You are free to use it for your own purposes, including any non-commercial research you are doing, and for the purposes of news reporting. Any other re-use (for example, commercial publication) would require the permission of the copyright holder. It is important that this data is not published for security reasons.

If you are unhappy with the service you have received in relation to your request and wish to request an internal review, you should email EIR@anglianwater.co.uk or write to:

General Counsel, Anglian Water Services, Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon PE29 6XU

If you are not content with the outcome of the internal review, you have the right to apply directly to the Information Commissioner for a decision. The Information Commissioner can be contacted at:

Information Commissioner's Office, Wycliffe House, Water Lane, Wilmslow, Cheshire SK9 5AF

If you have any queries about this email, please contact us via EIR@anglianwater.co.uk .

Yours sincerely

EIR Team

Anglian Water Services Limited

Lancaster House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU

Email EIR@anglianwater.co.uk